



REQUEST FOR PROPOSALS No. 21-017

Containerized Water Treatment Module

Addendum 1

Issued: March 12, 2021

Closing Date & Time: on or before 3:00 PM Pacific Time on April 8, 2021

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposal. Revisions supersede the information contained in the original Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

- 1. Clarification of design flow rate. The design maximum flow rate as shown in Appendix 2 is 200 US gallons per minute.**
- 2. Specification of typical duty cycle. A typical continuous duty cycle at this flow rate is 20%, or 4.8 hours in a 24 hour period.**

End of Addendum 1