



REQUEST FOR PROPOSALS No. 21-017

Containerized Water Treatment Module

Addendum 2

Issued: March 26, 2021

Closing Date & Time: on or before 3:00 PM Pacific Time on April 8, 2021

This addendum shall be read in conjunction with and considered as an integral part of the Request for Proposal. Revisions supersede the information contained in the original Proposal or previously issued Addendum. No consideration will be allowed for any extras due to any Proponent not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

- 1. Clarification of booster pump requirements. The booster pump should be designed to work with the following pipeline elements beyond the battery limit:**
 - a. A total of 30 metres of clean, new PVC pipe at the same diameter as the product water connection at the battery limit.**
 - b. 8 meters of static head.**
 - c. Open discharge to the top of a reservoir.**
- 2. Clarification of requirements related to COVID-19 and on-site commissioning. The manufacturer's commissioning team is required to comply with Regional District of Nanaimo (RDN) COVID protocols in place at the time of commissioning, which mirror the requirements set out by the provincial and federal governments. These requirements can be found at <https://www2.gov.bc.ca/gov/content/covid-19/info/response>. The RDN will work with the successful vendor to develop a site specific safety plan for commissioning.**

End of Addendum 2