



REQUEST FOR TENDER No. 21-054

Englishman River Hatchery Pedestrian Bridge Replacement

Addendum 2

Issued: June 30, 2021

Closing Date & Time: on or before 3:00 PM Pacific Time on July 8, 2021

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

Questions & Answers

- Q1. Is it acceptable to substitute 4"x8" cedar decking in place of the 4"x12" specification?
- A1. Deck planks must be 102mm x 305mm (4"x12"). This is governed by the maximum possible RTV (rough terrain vehicles) wheel loads and the cedar deck plank material.

End of Addendum 2