



## **REQUEST FOR TENDER No. 21-052**

### **Roof Shelter for Coal Car Display at Extension Miners Community Park**

#### **Addendum 1**

**Issued: July 20, 2021**


**Closing Date & Time: on or before 3:00 PM Pacific Time on August 11, 2021**

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

#### **Tender Addendum:**

Please see Tender Addendum 1 from the Project Engineer, Opus Engineering.

End of Addendum 1



## ADDENDUM No. S-1

PROJECT NAME	ADD #	DATE
Display Kiosk – Miners Community Park	S1	2021 July 20

Please note the following Addendum to the Structural Drawings:

This Addendum affects the entire structure, as follows:

1. Structural wood framing is to be supplied in accordance with General Note 5.0 – Structural Wood Framing. Grading shall be by visual or mechanical means in accordance with NLGA Standard Grading Rules for Canadian Lumber in accordance with the provisions of CSA Standard O141 Softwood Lumber. The grading is to be identified by the grade stamp on the lumber. No additional testing is required as long as the grading stamp is present.
2. Finish timber frame using *Weather One Solid Hide 100% Acrylic Stain 723 Series*, color by owner, or pre-approved alternate. Submit color chip to owner for approval. Supply extra 4L container for touch up.