



REQUEST FOR TENDER No. 21-052

Roof Shelter for Coal Car Display at Extension Miners Community Park

Addendum 3

1 page total

Issued: August 9, 2021

Closing Date & Time: on or before 3:00 PM Pacific Time on August 11, 2021

This addendum shall be read in conjunction with and considered as an integral part of the Request for Tender. Revisions supersede the information contained in the original Tender or previously issued Addendum. No consideration will be allowed for any extras due to any Vendor not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

QUESTIONS & ANSWERS:

- Q1. Is the roof rafter material which is labelled as 2"x10" SPF rough sawn full dimensional lumber, or is it a nominally dimensioned material that would be 1-1/2" x9-1/4" which is commonly described as 2x10 (note, no quote marks shown) that one could purchase in the lumber yard?
- A1. Please see Addendum 2, Opus Engineering S-2, and the structural drawings for lumber sizing.
- Q2. This item then moves to seek clarification on the remainder of the material, which is 8"x8" DFIR. This material is viewed as an 8" square post and NOT a 7-1/4" x7-1/4" post.
- A2. Please see Addendum 2, Opus Engineering S-2, and the structural drawings for lumber sizing.
- Q3. Lastly, although likely an error, this is an imperial job, and it seems unlikely that a welder will generate a 6" fillet weld vs a 1/4" fillet. They are noting the field weld shown as a 6 on the post saddle connection.
- A3. Your assumption is correct a 6" fillet is not possible in the locations shown.

End of Addendum 3