

CDWG=Canadian Drinking Water Guidelines

OG= Operational Guidance Value

MAC=Maximum Acceptable Concentration

AO= Asthetic Objective

Orange font indicates non-compliance with the Aesthetic Objective in the Canadian Drinking Water Guidelines (CDWG)
Red font indicates non-compliance with the Maximum Acceptable Concentration (MAC) in the CDWG

	Units	CDWG		May 13 2014	May 19 2015	May 10 2016	May 8 2017	May 7 2018	May 13 2019	May 21 2020	May 6 2021
Miscellaneous Inorganics											
Fluoride	mg/L	1.5	MAC	0.1	0.11	0.11	0.12	0.11	0.11	0.11	0.096
Alkalinity (total as CaCO ₃)	mg/L			140	128	141	144	127	137	130	140
Anions											
Dissolved Sulphate	mg/L	500	AO	25.8	22	29.5	26.4	27.6	28.4	36	29
Dissolved Chloride	mg/L	250	AO	9.4	11	12	12	11	12	13	14
Nitrite	mg/L	1	MAC	<0.05	<0.0050	<0.0050	<0.0050	<0.0050	<0.005	<0.005	<0.005
Miscellaneous											
Apparent Colour	Colour Unit			36	10	30	10	20	<2	20	20
Nutrients											
Total Ammonia	mg/L			<0.02	0.0099	0.016	0.11	0.028	<0.015	0.061	<0.015
Physical Properties											
Conductivity	µS/cm			337	331	350	344	336	354	350	360
pH	pH	7.0:10.5	AO	8.2	8.17	8.29	8.27	8.12	8.14	8.09	8.16
TDS	mg/L	500	AO	222	194	188	204	198	210	210	210
Turbidity	NTU			1.1	1.3	1.29	1.85	1.37	1.33	1.5	1.1
Microbiological Parameters											
E.coli	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0	0	0
Total Coliforms	MPN/100mL	<1	MAC	<1.0	<1.0	<1.0	<1.0	<1.0	0	0	0
Calculated Parameters											
Total Hardness (CaCO ₃)	mg/L			160	135	145	181	144	154	154	150
Nitrate	mg/L	10	MAC	<0.05	<0.020	<0.020	<0.020	<0.020	<0.02	<0.02	<0.02
Elements											
Total Mercury	mg/L	0.001	MAC	<0.00001	<0.00001	<0.00001	<0.00001	<0.000002	<0.000002	<0.0000019	<0.0000019
Total Metals											
Total Aluminum	mg/L	0.1	OG	<0.025	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003
Total Antimony	mg/L	0.006	MAC	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
Total Arsenic	mg/L	0.01	MAC	<0.00025	<0.00012	<0.0001	0.00012	<0.0001	<0.00012	<0.0001	<0.0001
Total Barium	mg/L	1	MAC	0.0169	0.0151	0.016	0.0191	0.015	0.0156	0.0163	0.163
Total Beryllium	mg/L			<0.00025	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Bismuth	mg/L			<0.0005	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Boron	mg/L	5	MAC	0.027	<0.050	<0.050	<0.050	<0.050	<0.05	<0.05	<0.05
Total Cadmium	mg/L	0.005	MAC	<0.00005	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Total Chromium	mg/L	0.05	MAC	<0.0025	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Cobalt	mg/L			<0.0005	<0.0005	<0.0005	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002
Total Copper	mg/L	1	AO	0.0025	0.00148	0.00069	0.0009	0.00102	0.00119	0.00096	0.00112
Total Iron	mg/L	0.3	AO	0.143	0.113	0.117	0.125	0.123	0.11	0.104	0.0905
Total Lead	mg/L	0.01	MAC	<0.0005	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002
Total Manganese	mg/L	0.02 0.12	AO MAC	0.139	0.125	0.123	0.142	0.127	0.107	0.105	0.124
Total Molybdenum	mg/L			0.00056	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Nickel	mg/L			<0.0010	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Total Selenium	mg/L	0.05	MAC	<0.0005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Silicon	mg/L			12.5	11.5	12.4	15.6	12.5	11.4	11.7	11.7
Total Silver	mg/L			<0.00025	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002
Total Strontium	mg/L			0.146	0.136	0.146	0.163	0.146	0.137	0.15	0.153
Total Thallium	mg/L			<0.00005	<0.00005	<0.00005	<0.00001	<0.00001	<0.00001	<0.00001	<0.00001
Total Tin	mg/L			<0.0005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Titanium	mg/L			<0.0025	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Uranium	mg/L	0.02	MAC	<0.00005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Vanadium	mg/L			<0.0005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Zinc	mg/L	5	AO	0.0188	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005
Total Zirconium	mg/L				<0.0005	<0.0005	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Total Calcium	mg/L			39	34	34.6	44.7	34.9	37.3	37.5	35.7
Total Magnesium	mg/L			15.1	12.2	14.2	16.9	13.7	14.7	14.5	14.7
Total Potassium	mg/L			2.6	2.29	2.48	3.05	2.32	2.49	2.5	2.53
Total Sodium	mg/L	200	AO	15.4	11.3	12.5	14.1	11.7	12.2	12	12.3
Total Sulphur	mg/L				8.8	8.8	10.9	8.8	9.4	9.7	8.8

Notes below about Manganese (2019) from: <https://www.canada.ca/en/health-canada/services/environmental-workplace-health/reports-publications/water-quality/guidelines-canadian-drinking-water-quality-summary-table.html>

Type	Parameter (published, reaffirmed)	MAC (mg/L)	Other value (mg/L)	Common sources of parameter in water	Health considerations	Comments
I= Inorganic chemical parameter	Manganese (2019)	0.12	AO: <0.02	Dissolution of naturally- occurring minerals commonly found in soil and rock. Other sources include industrial discharge, mining activities and leaching from landfills.	Health Basis of MAC: Effects on neurological development and behaviour; deficits in memory, attention, and motor skills. Other: Formula-fed infants (where water containing manganese at levels above the MAC is used to prepare formula) may be especially at risk.	AO based on minimizing the occurrence of discoloured water, consumer complaints and staining of laundry.